

4. 第三者機関による測定結果(煙突から排出される排ガス)

(1) ダイオキシン類濃度

規制値: 0.1ng-TEQ/m³N(O₂ 12%換算値)

	採取年月日	結果を得た年月日	測定結果
1号炉	2021/6/7	2021/7/5	0.000043
	2021/12/6	2022/1/21	0.0020
2号炉	2021/5/10	2021/5/28	0.000053
	2021/10/4	2021/11/2	0.0029
3号炉	2021/6/8	2021/7/5	0.00000012
	2021/12/7	2022/1/21	0.000092

(2) 硫黄酸化物排出量

規制値: 15.4[m³N/h] (K値=1.75)

	採取年月日	結果を得た年月日	測定結果
1号炉	2021/5/10	2021/5/24	0.227
	2021/6/7	2021/6/24	0.114
	2021/9/6	2021/9/17	0.039
	2021/10/4	2021/10/21	0.210
	2021/12/6	2022/1/7	0.082
	2022/3/7	2022/3/28	0.149
2号炉	2021/4/5	2021/4/13	0.222
	2021/5/10	2021/5/24	0.211
	2021/8/2	2021/8/12	0.096
	2021/10/4	2021/10/21	0.148
	2022/1/5	2022/1/19	0.115
	2022/3/7	2022/3/28	0.096
3号炉	2021/4/5	2021/4/13	0.174
	2021/6/8	2021/6/24	0.126
	2021/8/2	2021/8/12	0.079
	2021/12/7	2022/1/7	0.137
	2022/1/5	2022/1/19	0.090
	2022/2/7	2022/2/18	0.062

(3) ばいじん濃度

規制値: 0.04[g/m³N] (O₂ 12%換算値)

	採取年月日	結果を得た年月日	測定結果
1号炉	2021/5/10	2021/5/24	<0.001
	2021/6/7	2021/6/24	<0.001
	2021/9/6	2021/9/17	<0.001
	2021/10/4	2021/10/21	<0.001
	2021/12/6	2022/1/7	<0.001
	2022/3/7	2022/3/28	<0.001
2号炉	2021/4/5	2021/4/13	<0.001
	2021/5/10	2021/5/24	<0.001
	2021/8/2	2021/8/12	<0.001
	2021/10/4	2021/10/21	<0.001
	2022/1/5	2022/1/19	<0.001
	2022/3/7	2022/3/28	<0.001
3号炉	2021/4/5	2021/4/13	<0.001
	2021/6/8	2021/6/24	<0.001
	2021/8/2	2021/8/12	<0.001
	2021/12/7	2022/1/7	<0.001
	2022/1/5	2022/1/19	<0.001
	2022/2/7	2022/2/18	<0.002

(4) 塩化水素濃度

規制値: 700[mg/m³N] (O₂ 12%換算値)

	採取年月日	結果を得た年月日	測定結果
1号炉	2021/5/10	2021/5/24	17
	2021/6/7	2021/6/24	5
	2021/9/6	2021/9/17	6
	2021/10/4	2021/10/21	13
	2021/12/6	2022/1/7	2
	2022/3/7	2022/3/28	5
2号炉	2021/4/5	2021/4/13	15
	2021/5/10	2021/5/24	8
	2021/8/2	2021/8/12	9
	2021/10/4	2021/10/21	11
	2022/1/5	2022/1/19	5
	2022/3/7	2022/3/28	6
3号炉	2021/4/5	2021/4/13	11
	2021/6/8	2021/6/24	9
	2021/8/2	2021/8/12	8
	2021/12/7	2022/1/7	9
	2022/1/5	2022/1/19	5
	2022/2/7	2022/2/18	6

(5) 窒素酸化物濃度

規制値: 250[ppm] (O₂ 12%換算値)

	採取年月日	結果を得た年月日	測定結果
1号炉	2021/5/10	2021/5/24	30
	2021/6/7	2021/6/24	32
	2021/9/6	2021/9/17	32
	2021/10/4	2021/10/21	27
	2021/12/6	2022/1/7	31
	2022/3/7	2022/3/28	30
2号炉	2021/4/5	2021/4/13	30
	2021/5/10	2021/5/24	30
	2021/8/2	2021/8/12	28
	2021/10/4	2021/10/21	31
	2022/1/5	2022/1/19	27
	2022/3/7	2022/3/28	30
3号炉	2021/4/5	2021/4/13	32
	2021/6/8	2021/6/24	28
	2021/8/2	2021/8/12	29
	2021/12/7	2022/1/7	30
	2022/1/5	2022/1/19	29
	2022/2/7	2022/2/18	27