

#### 4. 第三者機関による測定結果(煙突から排出される排ガス)

##### (1) ダイオキシン類濃度

規制値: 0.1ng-TEQ/m<sup>3</sup>N(O<sub>2</sub> 12%換算値)

	採取年月日	結果を得た年月日	測定結果
1号炉	2022/5/9	2022/6/1	0.00023
	2023/12/5	2023/1/6	0.000036
2号炉	2022/6/6	2022/7/11	0.00014
	2023/12/6	2023/1/6	0.0020
3号炉	2022/6/7	2022/7/11	0.00023
	2022/10/3	2022/11/1	0.00013

##### (2) 硫黄酸化物排出量

規制値: 15.4[m<sup>3</sup>N/h] (K値=1.75)

	採取年月日	結果を得た年月日	測定結果
1号炉	2022/5/9	2022/5/17	0.087
	2022/7/4	2022/7/11	0.242
	2022/9/5	2022/9/14	0.106
	2022/12/5	2023/1/5	0.194
	2023/1/4	2023/1/17	0.089
	2023/2/6	2023/2/20	0.129
2号炉	2022/6/6	2022/7/1	0.178
	2022/7/4	2022/7/11	0.161
	2022/8/1	2022/8/10	0.247
	2022/10/3	2022/11/1	0.110
	2022/12/6	2023/1/5	0.061
	2023/3/6	2023/3/15	0.168
3号炉	2022/4/4	2022/4/15	0.072
	2022/5/9	2022/5/17	0.182
	2022/6/7	2022/7/1	0.088
	2022/9/5	2022/9/14	0.135
	2022/10/3	2022/11/1	0.163
	2023/2/6	2023/2/20	0.048

##### (3) ばいじん濃度

規制値: 0.04[g/m<sup>3</sup>N] (O<sub>2</sub> 12%換算値)

	採取年月日	結果を得た年月日	測定結果
1号炉	2022/5/9	2022/5/17	<0.001
	2022/7/4	2022/7/11	<0.001
	2022/9/5	2022/9/14	<0.001
	2022/12/5	2023/1/5	<0.001
	2023/1/4	2023/1/17	<0.001
	2023/2/6	2023/2/20	<0.001
2号炉	2022/6/6	2022/7/1	<0.001
	2022/7/4	2022/7/11	<0.001
	2022/8/1	2022/8/10	<0.001
	2022/10/3	2022/11/1	<0.001
	2022/12/6	2023/1/5	<0.001
	2023/3/6	2023/3/15	<0.001
3号炉	2022/4/4	2022/4/15	<0.001
	2022/5/9	2022/5/17	0.001
	2022/6/7	2022/7/1	<0.001
	2022/9/5	2022/9/14	<0.001
	2022/10/3	2022/11/1	<0.001
	2023/2/6	2023/2/20	<0.001

##### (4) 塩化水素濃度

規制値: 700[mg/m<sup>3</sup>N] (O<sub>2</sub> 12%換算値)

	採取年月日	結果を得た年月日	測定結果
1号炉	2022/5/9	2022/5/17	5
	2022/7/4	2022/7/11	12
	2022/9/5	2022/9/14	11
	2022/12/5	2023/1/5	13
	2023/1/4	2023/1/17	9
	2023/2/6	2023/2/20	10
2号炉	2022/6/6	2022/7/1	11
	2022/7/4	2022/7/11	12
	2022/8/1	2022/8/10	6
	2022/10/3	2022/11/1	5
	2022/12/6	2023/1/5	11
	2023/3/6	2023/3/15	10
3号炉	2022/4/4	2022/4/15	3
	2022/5/9	2022/5/17	9
	2022/6/7	2022/7/1	4
	2022/9/5	2022/9/14	14
	2022/10/3	2022/11/1	3
	2023/2/6	2023/2/20	8

##### (5) 窒素酸化物濃度

規制値: 250[ppm] (O<sub>2</sub> 12%換算値)

	採取年月日	結果を得た年月日	測定結果
1号炉	2022/5/9	2022/5/17	33
	2022/7/4	2022/7/11	30
	2022/9/5	2022/9/14	31
	2022/12/5	2023/1/5	32
	2023/1/4	2023/1/17	25
	2023/2/6	2023/2/20	28
2号炉	2022/6/6	2022/7/1	31
	2022/7/4	2022/7/11	31
	2022/8/1	2022/8/10	30
	2022/10/3	2022/11/1	30
	2022/12/6	2023/1/5	29
	2023/3/6	2023/3/15	28
3号炉	2022/4/4	2022/4/15	33
	2022/5/9	2022/5/17	31
	2022/6/7	2022/7/1	31
	2022/9/5	2022/9/14	30
	2022/10/3	2022/11/1	27
	2023/2/6	2023/2/20	29